

Byrne Residence Roofing Screws

<u>Row (Panel)</u>	<u>Total Screws</u>	<u>Originally Stripped</u>	<u>%</u>	<u>Currently Stripped</u>	<u>%</u>	<u>Screws that needed dowels & adhesive in 2017</u>	<u>Screws that needed dowels & adhesive in 2018</u>	<u>Screws that needed dowels & adhesive in 2019</u>
East								
1	120	32	26.7%	1	0.8%	1	1	3
2	120	29	24.2%	2	1.7%	0	4	1
3	120	40	33.3%	1	0.8%	2	0	2
4	120	37	30.8%	0	0.0%	1	1	4
5	120	40	33.3%	1	0.8%	1	3	1
6	120	35	29.2%	1	0.8%	0	2	0
7	120	41	34.2%	1	0.8%	1	2	1
8	120	41	34.2%	1	0.8%	1	0	1
9	120	56	46.7%	0	0.0%	2	1	1
10	120	47	39.2%	1	0.8%	2	1	3
11	120	47	39.2%	1	0.8%	0	2	1
12	120	57	47.5%	0	0.0%	1	1	0
13	160	56	35.0%	1	0.6%	1	2	2
14	160	36	22.5%	0	0.0%	0	1	2
15	160	35	21.9%	0	0.0%	1	0	1
16	160	34	21.3%	1	0.6%	2	0	0
17	160	36	22.5%	1	0.6%	1	0	0
18	160	26	16.3%	0	0.0%	0	1	0
19	160	24	15.0%	1	0.6%	0	3	0
20	160	32	20.0%	1	0.6%	2	0	0
21	90	40	44.4%	0	0.0%	2	1	0
22	90	36	40.0%	0	0.0%	1	0	0
23	90	24	26.7%	1	1.1%	1	1	0
24	90	28	31.1%	0	0.0%	0	0	0
25	90	26	28.9%	0	0.0%	1	0	0
26	80	19	23.8%	0	0.0%	1	0	0
West	3250	954	29.4%	16	0.5%	25	27	23

Statistics noted above refer to #9, zinc-plated, 1 1/2" long, 1/4" socket head roofing screws.

As of June 1, 2016, updated April/May 2017, 2018, 2019.